

LED EMERGENCY EXIT SIGN - WSD Series CR

TYPE: CR-7037R;CR-7037G

LED Emergency Exit Sign accord with US STANDARD - Injection-molded, flame-retardant and high impact thermoplastic housing. This exit sign with design is great for placing on doorways, isles, restaurant, office building and warehouses.





CR-7037R

CR-7037G






Standard:Double-Face free parts in package

	SPECIFICATION	
TYPE	CR-7037R / CR-7037G	
WORKING VOLTAGE	120V / 277V 50Hz/60Hz	
EFFICACY	0.86	
POWER CONSUMPTION	4 W	
INPUT CURRENT	100mA	
RECHARGE TIME	24 Hours	
OUTPUT WATTAGE	1W	
EMERGENCY DURATION	≥90 Mins	
BATTERY	1.2V	
FACTORY SETTING	Double-Face free parts in package	
ENVIRONMENT	DAMP	
WORKING TEMPERATURE	0°C ~ 40°C	
CERTIFICATION	UL	
CABLE	Input Connect, No cable	
WARRANTY	2 year limited	

DIMENSION:



LED EMERGENCY EXIT SIGN - WSD Series CR

TYPE: CR-7037R;CR-7037G

ORDERING INFORMATION

EXAMPLE:

CR-7037R / CR-7037G

CR	7037	R
CODE	CODE	FINISH
WSD LED	7037 Product Code	G(Green) R(Red)

ACCESSORIES (Standard)




CR-7037R / CR-7037G

WIRING DIAGRAM:

CR-7037R / CR-7037G

Make the proper supply wire connections. If using 120VAC, connect the black and White wires to the building utility. If using 277VAC, connect the Orange and White wires to the building utility.





LED EMERGENCY EXIT SIGN - WSD Series CR

TYPE: CR-7037R;CR-7037G


Mounting Instructions

NOTE: First turn off electricity.


1.Remove mounting plate from fixture.



Knockout in back of mounting plate and push wires through the hole.



3.Securely attach mounting plate to J-box (not provided).



4.ELECTRICAL CONNECTIONS

Make the proper supply wire connections.

If using 120VAC, connect the black and White wires to the building utility.

If using 277VAC, connect the Orange and White wires to the building utility.

